

# STANDARD CABINET FRAMES



## Product Features

### Finish

- Black textured powder paint finish


### Structure

- Frame constructed of rugged 13GA steel
- Fully welded for rigidity
- 83" tall cabinet, with up to 44 U-Space of vertical capacity
- Comes standard with 4 adjustable leveling feet
- Maximum opening in the base of the cabinet
- Standard mounting locations for left or right opening doors
- Full horizontal adjustment for shelving and components
- Includes provisioning for 4 ground lugs (1 supplied)
- "Flex Top" design allows for multiple configurations

### Options

Standard cabinet frames support the full line of CableTalk:

- Doors
- Cover plates
- Shelves
- Power solutions
- Ganging kit
- Extension Chimneys
- Fan/cable knock-outs
- Side panels
- Mounting angles
- Cable Management System
- Casters, swivel and fixed
- Cooling fans
- Cable trough
- Chimney top



CTC3-3042-B



Perforated top construction available. Check Flex-top flyer for part number. Other sizes available on request

**Note:** All of our cabinets are fully customizable. If desired options are not listed, speak with your CableTalk representative.

Mounting angles sold separately. Shown with optional caster plates.

## Standard Dimensions

### Standard Frames

Part No.	Description	Width (Inches)	Depth (Inches)	Height (Inches)	U-Space
CTC3-2436-B	24W x 36D x 83H Frame	24	36	83	44
CTC3-2442-B	24W x 42D x 83H Frame	24	42	83	44
CTC3-3030-B	30W x 30D x 83H Frame	30	30	83	44
CTC3-3036-B	30W x 36D x 83H Frame	30	36	83	44
CTC3-3042-B	30W x 42D x 83H Frame	30	42	83	44
CTC3-3048-B	30W x 48D x 83H Frame	30	48	83	44

### Caster Plate Kits

Part No.	Description	Width (Inches)
CTC-K-48-24CAB	Caster plate kit for 24W cabinet	24
CTC-K48-30CAB	Caster plate kit for 30W cabinet	30

### Note:

- Caster plate must be specified at time of purchase for factory installation.
- Caster option ordered with frame will be factory installed.



www.cabletalk.com | info@cabletalk.com  
 Canada & USA 1-800-267-7282  
 DATA SUBJECT TO CHANGE WITHOUT NOTICE

Section 1.2  
 Page 7

COLE-CT-TM 2018-08-15